


SUMP PUMPS

SPV50 Performance Data

RPM: **1750** Discharge: **1-1/2" NPT** Solids: **1/4"**

Performance Curve



Performance Data

Total Lift (feet)	0	5	10	15	20	26
GPM	85	74	63	47	31	0



P U M P

Honest, Professional, Dependable

1899 Cottage Street, Ashland, Ohio 44805
Telephone: 855 281-6830 · Fax: 877 326-1994 · ashlandpump.com